

1	REVISED BASEMENT PLAN	12-14-18
NO	REVISION	DATE



OBERMILLER NELSON
ENGINEERING

Mechanical Design Consultants

2201 12th Street North Fargo, ND 58102

Utleg engineers

Utleg Engineers, Inc. 2000 38th Avenue South Fargo, North Dakota 58104

1 BASEMENT DEMOLITION PLAN

E2 1/8"=1'-0"


I hereby certify that this plan specification, or report was prepared by me or under my direct supervision, and that I am duly registered Engineer under the laws of the State of Minnesota.

Print Name: _____

Date: _____ Reg. No. _____

APPROVED: SERVICE LINE ENGINEER	DATE: _____	APPROVED: INFECTIOUS DISEASE WORK	DATE: _____
APPROVED: SERVICE LINE ENGINEER	DATE: _____	APPROVED: FUTURE SAFETY	DATE: _____
APPROVED: SELECTS SECTION NUMBER	DATE: _____	APPROVED: CHIEF OF POLICE	DATE: _____
APPROVED: SERVICE LINE	DATE: _____	APPROVED: SAFETY WORKER	DATE: _____

PROJECT TITLE	PROJECT NO.	DATE	SCALE
BASEMENT DEMOLITION PLAN	BASEMENT HVAC	29	1/8"=1'-0"
APPROVED: CHIEF OF POLICE	DATE: _____	CHIEF	DATE: _____
APPROVED: SERVICE LINE ENGINEER	DATE: _____	STATIONING: No. 10000	DATE: _____
PROJECT NO.	PROJECT NO.	PROJECT NO.	PROJECT NO.
E2	1/8"=1'-0"	1/8"=1'-0"	1/8"=1'-0"



2 FIRST FLOOR DEMOLITION - BATH 143

E2 1/8"=1'-0"

GENERAL NOTES:

1. PROVIDE SUPPORT FOR ANY CABLING, CONDUIT OR OTHER WIRING SYSTEMS THAT MAY BE LAYING OR ATTACHED TO THE CEILING. PROVIDE SUPPORT IN ACCORDANCE WITH SPECIFICATION SECTION 271001 AND THE NEC.
2. DISCONNECT ALL LIGHT FIXTURES, PA SPEAKERS, EXIT SIGNS, AND FIRE ALARM SYSTEM EQUIPMENT LOCATED IN CEILINGS.
3. EXISTING POWER DEVICES TO BE DEMOLISHED WITHIN FIRE STOPPING SHALL BE REMOVED FROM THE WALL. SWITCHES, ETC. SHALL BE RETURNED TO OWNER'S STOCK FOR HIS ACCEPTANCE OR REFUSAL. ALL MATERIAL REJECTED BY THE OWNER SHALL BE REMOVED FROM THE SITE OR REUSED BY THE DIVISION 26 CONTRACTOR.
4. ALL EXISTING CONDUCTORS/CONDUIT TO BE REMOVED FROM THE CEILING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL OF ALL EXISTING POWER, DATA/TELECOM, FIRE ALARM, AND LIGHTING. SOME NEW CONDUCTOR/CONDUIT MAY BE DEACTIVATED DURING DEMOLITION.
5. UNLESS OTHERWISE INDICATED SYSTEMS AND EQUIPMENT SHALL BE REMOVED FROM THE CEILING. THE CONTRACTOR SHALL COORDINATE WITH OTHER TRADES AND CONDUCT THE DEMOLITION AND REMODEL TO AVOID DAMAGING EXISTING SYSTEMS AND INSTALLATIONS TO REMAIN. DAMAGE TO ANY EXISTING SYSTEMS AND EQUIPMENT SHALL BE REPAIR OR REPLACE TO ITS ORIGINAL CONDITION/FUNCTION AT NO COST TO THE OWNER.
6. ALL PA SPEAKERS IN THE SCOPE OF WORK ARE TO BE REMOVED FROM THE CEILING GRID DURING THE DEMOLITION PHASE, SALVAGED, ACCEPTABLY CLEANED, AND REMOUNTED IN THE NEW CEILING GRID. REFERENCE DRAWING E3 FOR NEW SPEAKER LOCATIONS.

PLAN NOTES:

1. EXISTING TYPE 'A1' FIXTURE SALVAGED FROM DEMOLITION. REUSE FOR REMODEL PHASE AS SHOWN ON DRAWING E3. REFERENCE LIGHTING FIXTURE REQUIREMENTS.
2. EXISTING TYPE 'B1' FIXTURE SALVAGED FROM DEMOLITION. REUSE FOR REMODEL PHASE AS SHOWN ON DRAWING E3. REFERENCE LIGHTING FIXTURE REQUIREMENTS.
3. EXISTING TYPE 'C1' FIXTURE SALVAGED FROM DEMOLITION. REUSE FOR REMODEL PHASE AS SHOWN ON DRAWING E3. REFERENCE LIGHTING FIXTURE REQUIREMENTS.
4. FOR EXISTING CONDENSING UNIT, REMOVE ELECTRICAL CONNECTION, DISCONNECT SWITCH AND CONDUIT/CONDUCTORS BACK TO THE SOURCE OF SUPPLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL OF ALL EXISTING POWER, DATA/TELECOM, FIRE ALARM, AND LIGHTING. SOME NEW CONDUCTOR/CONDUIT MAY BE DEACTIVATED DURING DEMOLITION.